

Section 3813 is added to read as follows: Underground Liquefied Petroleum Gas Tank Installations.

Section 3813.1 of Chapter 38 of the Fire Code of the Diamond Springs - El Dorado Fire Protection District is added to read as follows, based on climatic, geological and topographical conditions:

Section 3813.1 is added to read as follows: Permits and Plans.

3813.1 - Permits and Plans. Permits shall be required and plans shall be submitted for all underground tank installations and approved by the Fire AHJ.

Appendix B – Fire Flow Requirements for Buildings

Section B105 – Fire-Flow Requirements for Buildings:

Section B105.1 shall be amended as follows:

Section B105.1 of Appendix B of the Fire Code of the Diamond Springs - El Dorado Fire Protection