## **DEVELOPMENT SERVICES DEPARTMENT**

## **COUNTY OF EL DORADO**

http://www.co.el-dorado.ca.us/devservices



PLACERVILLE OFFICE:
2850 FAIRLANE COURT PLACERVILLE, CA 95667
BUILDING (530) 621-5315 / (530) 622-1708 FAX
bldqdept@co.el-dorado.ca.us
PLANNING (530) 621-5355 / (530) 642-0508 FAX
planning@co.el-dorado.ca.us
Counter Hours: 8:00 AM to 4:00 PM

LAKE TAHOE OFFICE:
3368 LAKE TAHOE BLVD. SUITE 302
SOUTH LAKE TAHOE, CA 96150
(530) 573-3330
(530) 542-9082 FAX
tahoebuild@co.el-dorado.ca.us
Counter Hours: 8:00 AM to 4:00 PM

TO:

**Planning Commission** 

Agenda of:

September 10, 2009

FROM:

Jason R. Hade, AICP, Senior Planner

Item #:

10

DATE:

September 1, 2009

RE:

Parcel Map P09-0002/Kovach; Revised Conditions of Approval

Based on the attached project comments received from the El Dorado County Fire Protection District on August 17, 2009, staff recommends the following additions to Attachment 1 – Conditions of Approval.

## El Dorado County Fire Protection District

- 38. A site review fee of \$120.00 shall be submitted to the El Dorado County Fire Protection District prior to filing the parcel map.
- 39. Prior to filing the parcel map, documentation from the El Dorado Irrigation District indicating a fire flow of 1,000 gallons per minute at 20 pounds per square inch shall be submitted to the El Dorado County Fire Protection District.

Attachment



## EL DORADO COUNTY FIRE PROTECTION DISTRICT

P.O. Box 807/4040 Carson Road / Camino, CA 95709 (530) 644-9630 Fax (530) 644-9636

August 3, 2009

County of El Dorado **Planning Department** 2950 Fair Lane Court Placerville, CA, 95667 Attention: Pierre Rivas

RE: P09-0002, A09-0001, Z09-0001, Kovach Parcel Map, French Creek @ Altair. P09-0003, 469-0

The TPM is approved with the following conditions:

- 1. Submit review fee of \$ 120.00.
- 2. Fire flow for this project is 1000 gpm @ 20 psi for two hrs.
- 3. Hydrant position that shown is accepted.
- 4. Show documentation from EID (FIL) and the Fire District, that the water and documentation from EID (FIL) and the Fire District, that the water and documentation from EID (FIL) and the Fire District, that the water and documentation from EID (FIL) and the Fire District, that the water and documentation from EID (FIL) and the Fire District, that the water and documentation from EID (FIL) and the Fire District, that the water and documentation from EID (FIL) and the Fire District, that the water and documentation from EID (FIL) and the Fire District, that the water and documentation from EID (FIL) and the Fire District, that the water and documentation from EID (FIL) and the Fire District is the fire District in the fire District in the fire District in the water and documentation from EID (FIL) and the Fire District in the system will meet fire flow.
- 5. El Dorado County DOT standards will be met at a minimum and will 3. Golado Olo at supersede Fire District minimum requirements.
- 6. The above requirements to be completed prior to final map.

Best regards,

Mark A. Johnson Mark A. Johnson

Fire Marshal

Cc: file, DOT

Approval because of this process shall not be construed to be an approval of a violation of the provisions of the California edition of the uniform Fire Code or other codes, regulations and ordinances of the Fire District.

hall PM is approved.

. It was a series of a

F Midail tooshord

ornas an tenhoreno, fi

a aemisõe Pla Nis

The above remies

en remarks