



Legislation Details (With Text)

File #: 23-1190 **Version:** 1

Type: Agenda Item **Status:** Approved

File created: 6/12/2023 **In control:** Board of Supervisors

On agenda: 6/27/2023 **Final action:** 6/27/2023

Title: Information Technologies Department recommending the Board ratify the emergency purchase and addition of a replacement Uninterruptible Power Supply for Briw Road to the Fiscal Year 2022-23 Fixed Asset List.

FUNDING: General Fund.

Sponsors:

Indexes:

Code sections:

Attachments:

Date	Ver.	Action By	Action	Result
6/27/2023	1	Board of Supervisors	Approved	Pass

Information Technologies Department recommending the Board ratify the emergency purchase and addition of a replacement Uninterruptible Power Supply for Briw Road to the Fiscal Year 2022-23 Fixed Asset List.

FUNDING: General Fund.

DISCUSSION / BACKGROUND

On the evening of Wednesday, May 31, 2023, the County experienced a failure of the Uninterruptible Power Supply (UPS) battery back-up for the Health and Human Services Agency (HHSA) at Briw Road in Placerville. Information Technologies (IT) moved forward with an emergency purchase, as defined by the County Purchasing Policy C-17, Section 2.9, as an "unexpected and pressing situation which requires swift and immediate procurement action precluding regular procurement policy and is essential to public life, health, safety, or improved property of the County." Replacement parts were not available for this unit, as it has special load and wattage requirements.

The UPS battery was scheduled to be replaced in the Fall of 2023, however, system failure has led to adjustment of the replacement schedule so that the UPS unit can be replaced as soon as possible. In the event of a power outage, the UPS unit operates as a battery back-up to bridge the power supply until the generator power supply is available for the Briw Road location. Not having this back-up power supply in place could cause a loss of data, creating rework for the HHSA staff and downtime of the network, which could have significant impact on the department and services provided to the public.

The cost of the UPS battery replacement equipment is \$8,279.66.

ALTERNATIVES

N/A

PRIOR BOARD ACTION

N/A

OTHER DEPARTMENT / AGENCY INVOLVEMENT

Procurement & Contracts

CAO RECOMMENDATION / COMMENTS

Approve as recommended.

FINANCIAL IMPACT

There are savings available in IT's Fiscal Year 2022-23 Budget for this purchase.

CLERK OF THE BOARD FOLLOW UP ACTIONS

N/A

STRATEGIC PLAN COMPONENT

Infrastructure, Good Governance

CONTACT

Tonya Digiorno, Director of Information Technologies