



County of El Dorado

330 Fair Lane, Building A
Placerville, California
530 621-5390
FAX 622-3645
www.edcgov.us/bos/

Legislation Details

File #: 14-1480 **Version:** 1

Type: Agenda Item **Status:** Approved

File created: 10/23/2014 **In control:** Board of Supervisors

On agenda: 12/2/2014 **Final action:** 12/2/2014

Title: Community Development Agency, Development Services Division, recommending the Board consider the following pertaining to the 2013 Fire Code regarding Tahoe Basin Fire Agencies:
1) Adopt Resolution 221-2014 regarding the Lake Valley Fire Protection District and Resolution 222-2014 regarding the Meeks Bay Fire Protection District to do the following:
a) Ratify the Fire Agency Amendments to the 2013 Fire Code, with clarifications;
b) Delegate enforcement authority of the Fire Code to the Fire Chief of the local Fire Agencies except for one and two family dwellings; and
c) Delegate the Building Official as an agent of the Fire District for enforcement of the Fire Code of one and two family dwellings. The local Fire District shall remain the authority; and
2) Do not approve 2013 Fire Code Amendments to Sections: 903.2.8.2 and 903.2.8.3 which requires sprinkler systems to additions and alterations because this contradicts the 2013 California Residential Code Section R313 which specifically excludes this requirement.

Sponsors:

Indexes:

Code sections:

Attachments: 1. A - Reso Lake Valley 12-2-14, 2. B - Reso Meeks Bay 12-2-14, 3. C - Ltr Fire Prevent Officer Assoc 12-2-14, 4. D - East Slope Fire Dist Map 12-2-14, 5. E - Blue Route 12-2-14, 6. Executed Resolution 221-2014 12-2-14 item 33.pdf, 7. Executed Resolution 222-2014 12-2-14 item 33.pdf

Date	Ver.	Action By	Action	Result
12/2/2014	1	Board of Supervisors	Approved	Pass